

July 30, 2009

REVISED COPY

WATER-RIGHT, INC.
KURT GRUETT
1900 PROSPECT CT
APPLETON WI 54914-9000

Re: Description: WATER TREATMENT DEVICE- SOFTENER
Manufacturer: WATER-RIGHT, INC.
Product Name: MCDERMOTT SANITIZER PLUS SERIES CONDITIONERS (POE)
Model Number(s): PESAS1-1054MP AND PESAS1-1354MP (POE)
Product File No: 20090262

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.
- Operation of this/these device(s) and flow rates above the rated service flow rates indicated within this approval letter are not supported or acknowledged by this approval. The rated service flow rate(s) is/are the flow rate(s) at which this/these device(s) were tested.

Because the level of treatment obtained is a function of how long the water is in contact with the treatment media within this/these device(s), arbitrary increases in the flow rate(s), above the rated service flow rate(s) may compromise the quality of the treated water.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 3 of this letter.

WATER SOFTENING CAPABILITIES
PRODUCT FILE NUMBER 20090262
TABLE 1 OF 3

Model Numbers	Capacities*						Flow Rates vs. Pressure Losses
	Rating 1		Rating 2		Rating 3		
McDermott Sanitizer Plus Series	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
Metered							
PESAS1-1054MP	16,400	6.1	20,700	12.4	22,600	15.9	9.0 @ 3.4
PESAS1-1354MP	28,300	9.5	33,600	15.9	36,900	21.2	9.0 @ 2.8

* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 of 3 were conducted in accordance with column testing performed by Baumbach Labs.

AESTHETIC TREATMENT CAPABILITIES
PRODUCT FILE NUMBER 20090262
TABLE 2 OF 3

Model Numbers	Combined Total Iron (Fe ⁺² + Fe ⁺³) and Manganese (Mn ⁺²)	
	Influent (mg/l ¹)	Effluent (mg/l ¹)
McDermott Sanitizer Plus Series		
PESAS1-1054MP	≤ 10.0	≤ 0.3
PESAS1-1354MP	≤ 15.0	≤ 0.3

Other conditions: The tests run to generate the data for table 2 of 3 were conducted in accordance with column testing performed by Baumbach Labs. The total cumulative concentrations of hardness, total iron and manganese must be used to determine the proper sizing and programming of these products

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 ≤ = less than or equal to

* = unless otherwise indicated

pH MODIFICATION CAPABILITIES
PRODUCT FILE NUMBER 20090262
TABLE 3 OF 3

Model Numbers	pH	
	Influent (pH Units)	Effluent (pH Units)
McDermott Sanitizer Plus Series		
PESAS1-1054MP	≥ 6.0	≤ 7.0
PESAS1-1354MP	≥ 6.0	≤ 7.0

Other conditions: The tests run to generate the data for table 3 of 3 were conducted in accordance with column testing performed by Baumbach Labs.

≤ = less than or equal to

≥ = greater than or equal to

Water-Right, Inc.
July 30, 2009
Page 3 of 3
Product File No.: 20090262

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**
(608) 267-9566 **Fax**
glen.schlueter@wi.gov **Email**
8:00AM – 4:30PM CDT **Work Hours**

GWS:gws

July 30, 2009

REVISED COPY

WATER-RIGHT, INC.
KURT GRUETT
1900 PROSPECT CT
APPLETON WI 54914-9000

Re: Description: WATER TREATMENT DEVICE- SOFTENER
Manufacturer: WATER-RIGHT, INC.
Product Name: MCDERMOTT SANITIZER PLUS SERIES CONDITIONERS (POE)
Model Number(s): PESAS2-1054MP AND PESAS2-1354MP (POE)
Product File No: 20090261

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.
- Operation of this/these device(s) and flow rates above the rated service flow rates indicated within this approval letter are not supported or acknowledged by this approval. The rated service flow rate(s) is/are the flow rate(s) at which this/these device(s) were tested.

Because the level of treatment obtained is a function of how long the water is in contact with the treatment media within this/these device(s), arbitrary increases in the flow rate(s), above the rated service flow rate(s) may compromise the quality of the treated water.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES
 PRODUCT FILE NUMBER 20090261
 TABLE 1 OF 2**

Model Numbers	Capacities*						Flow Rates vs. Pressure Losses
	Rating 1		Rating 2		Rating 3		
McDermott Sanitizer Plus Series	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
Metered							
PESAS2-1054MP	22,900	6.1	32,000	12.4	34,800	15.9	9.0 @ 4.2
PESAS2-1354MP	28,200	9.3	48,300	15.9	60,300	26.5	9.0 @ 3.3

* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 of 2 were conducted in accordance with column testing performed by Baumbach Labs.

**AESTHETIC TREATMENT CAPABILITIES
 PRODUCT FILE NUMBER 20090261
 TABLE 2 OF 2**

Model Numbers	Combined Total Iron (Fe ⁺² + Fe ⁺³) and Manganese (Mn ⁺²)	
McDermott Sanitizer Plus Series	Influent (mg/l ¹)	Effluent (mg/l ¹)
PESAS2-1054MP	≤ 10.0	≤ 0.3
PESAS2-1354MP	≤ 15.0	≤ 0.3

Other conditions: The tests run to generate the data for table 2 of 2 were conducted in accordance with column testing performed by Baumbach Labs. The total cumulative concentrations of hardness, total iron and manganese must be used to determine the proper sizing and programming of these products

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 ≤ = less than or equal to

* = unless otherwise indicated

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
 Engineering Consultant-Plumbing Product Reviewer
 Bureau of Integrated Services
 Safety and Buildings Division
 Department of Commerce
 (608) 267-1401 **Phone**
 (608) 267-9566 **Fax**
 glen.schlueter@wi.gov **Email**
 8:00AM – 4:30PM CDT **Work Hours**

GWS:gws